



检测报告

No. A2D6260020001L

委托单位 北京南宫生物质能源有限公司

受测单位 北京南宫生物质能源有限公司

报告日期 2023年07月21日



声明
Statement

1. 本报告无检验检测专用章、报告骑缝章和批准人签章无效。
This report is invalid without special seal for inspection and test, cross-page seal and signature of the approver.
2. 本报告页面所使用“PONY”、“谱尼”字样为本单位的注册商标, 其受《中华人民共和国商标法》保护, 任何未经本单位授权的擅自使用和仿冒、伪造、变造“PONY”、“谱尼”商标均为违法侵权行为, 本单位将依法追究其法律责任。
The words "PONY" and "谱尼" used in this report page are the registered trademarks of the company, which are protected by the Trademark Law of the People's Republic of China. Any unauthorized use, counterfeiting, forging or altering of the trademarks of "PONY" and "谱尼" without the authorization of the company is an illegal infringement, and the company will investigate their legal liabilities according to law.
3. 委托单位对报告数据如有异议, 请于报告完成之日起十五日内(初级农产品报告请于报告收到之日起五日内)向本单位书面提出复测申请, 同时附上报告原件并预付复测费。
If the applicant has any objection to the report data, please submit a written application for retesting to PONY within 15 days after the completion of the report (for the report of primary agricultural products, submit a written application for retesting to the unit within 5 days after the receipt of the report), with the original report attached and the retesting fee prepaid.
4. 委托单位办理完毕以上手续后, 本单位会尽快安排复测。如果复测结果与异议内容相符, 本单位将退还委托单位的复测费。
After the applicant completes the above procedures, PONY shall arrange the retesting as soon as possible. If the retest result is consistent with the objection, PONY will refund the retest fees.
5. 不可重复性或不能进行复测的实验, 不进行复测, 委托单位放弃异议权利。
If the experiment cannot be repeated or cannot be retested, no retest shall be conducted, and the applicant shall waive the right of objection.
6. 委托单位对送检样品的代表性和资料的真实性负责, 否则本单位不承担任何相关责任。
The applicant is responsible for the representativeness of the commissioned samples and the authenticity of the documents, otherwise PONY does not assume any relevant responsibilities.
7. 本报告仅对所测样品的检测结果负责, 检测结果及其相关判定结论仅反映对所测样品的评价或只代表检测时污染物的排放状况。对于报告及所载内容不能进行商业广告宣传使用, 使用所产生的直接或间接损失及一切法律后果, 本单位不承担任何经济和法律责任。
This report is only responsible for the test results of the tested samples, The test results and relevant conclusions reflect the evaluation of the tested samples or only represent the emission status of pollutants during the test. The report and the contents contained in it cannot be used for commercial advertising, and PONY does not assume any economic and legal liabilities for direct or indirect losses and all legal consequences arising from the use.
8. 本单位有权在完成报告后按规定方式处理所测样品, 除客户特别声明并支付样品管理费, 所有超过标准规定时效期的样品均不再做留样。
PONY has the right to dispose the tested sample after approval of the test report. Unless the applicant specifically declares and pays the sample management fee, all samples beyond the validity period specified in the standard will not be retained.
9. 本单位保证工作的客观公正性, 对委托单位的商业信息、技术文件等商业秘密履行保密义务。
PONY assures objectivity and impartiality of the test, and fulfills the obligation of confidentiality for applicant's commercial information, and technique document.
10. 本报告私自转让、盗用、冒用、涂改、未经本单位批准的复制(全文复制除外)或以其它任何形式的篡改均属无效, 本单位将对上述行为追究其相应的法律责任。
Any unauthorized transfer, appropriation, falsification, alteration, copying (except full text copying) or alteration in any other form of this report without the approval of PONY shall be invalid. PONY shall strictly investigate the corresponding legal liability for the aforesaid behavior.

▲ 防伪说明(Anti-counterfeiting Instructions):

1. 报告编号是唯一的;
The report number is unique.
2. 扫描报告首页下方二维码, 即可查询报告真伪。
Scan the QR code below the first page to check the authenticity of the report.



全国服务热线
400-819-5688

WWW.PONYTEST.COM






微信订阅号 微博订阅号

- | | | | |
|----------------------------|--------------------------|------------------------|------------------------|
| 北京实验室:(010)83055000 | 哈尔滨实验室:(0451)58627755 | 内蒙古医学实验室:(0471)3591511 | 武汉实验室:(027)83997127 |
| 北京医学实验室:(010)62450233-8010 | 黑龙江医学实验室:(0451)58603455 | 太原实验室:(0351)7555722 | 武汉医学实验室:(027)85446975 |
| 北京谱尼科技公司:(010)80415661 | 郑州实验室:(0371)69350670 | 成都实验室:(028)87702708 | 杭州实验室:(0571)87219096 |
| 青岛实验室:(0532)88706866 | 郑州谱尼医学实验室:(0371)63273066 | 贵州实验室:(0851)85221000 | 杭州医学实验室:(0571)87219096 |
| 青岛医学实验室:(0532)88706866 | 新疆实验室:(0991)6684186 | 上海实验室:(021)64851999 | 宁波实验室:(0574)87977185 |
| 天津实验室:(022)23607888 | 石家庄实验室:(0311)85376660 | 上海医学实验室:(021)64851999 | 合肥实验室:(0551)63843474 |
| 天津医学实验室:(022)23607888 | 西安实验室:(029)89608785 | 苏州实验室:(0512)62997900 | 深圳实验室:(0755)26050909 |
| 长春实验室:(0431)80530198 | 西安创尼实验室:(029)81123093 | 苏州汽车安全带及儿童安全座椅 | 深圳医学实验室:(0755)26050909 |
| 吉林医学实验室:(0431)80529700 | 西安壹德威克实验室:(029)62686619 | 碰撞实验室:(0512)62997900 | 广州实验室:(020)89224310 |
| 大连实验室:(0411)87336618 | 西安医学实验室:(029)89608785 | 苏州医学实验室:(0512)62997900 | 南宁实验室:(0771)5518818 |
| 大连医学实验室:(0411)87336618 | 呼和浩特实验室:(0471)3450025 | 武汉车管所:(027)82318175 | 厦门实验室:(0592)5568048 |

检测报告

No. A2D6260020001L

第 1 页, 共 5 页

委托单位	北京南宫生物质能源有限公司		
受测单位	北京南宫生物质能源有限公司		
受测地址	北京市大兴区青云店镇南大红门村南宫生活垃圾焚烧厂		
采样位置	见数据页		
样品名称	有组织废气	检测类别	采样检测
采样日期	2023-07-05	检测日期	2023-07-05~2023-07-18
样品状态	滤筒+XAD-2 树脂+冷凝水	检测环境	符合要求
检测项目	二噁英类		
检测方法	环境空气和废气 二噁英类的测定 同位素稀释高分辨气相色谱-高分辨质谱法 HJ 77.2-2008		
所用主要仪器	智能废气二噁英采样仪(仪器型号:崂应 3030B,仪器编号:IE-4228),烟气分析仪(仪器型号:350,仪器编号:IE-3277),阻容法烟气含湿量检测器(仪器型号:1062A,仪器编号:IE-3558),高分辨双聚焦磁质谱(仪器型号:Thermo Scientific Trace1310 DFS,仪器编号:IE-3867)		
备注	该报告中检测方法由委托单位指定。		
编制人		审核人	
批准人		签发日期	2023 年 07 月 21 日

检测报告

No. A2D6260020001L

第 2 页, 共 5 页

检测结果:

样品名称和编号	检测项目	简称	实测浓度	换算浓度	毒性当量(TEQ)		
			ng/m ³	ng/m ³	I-TEF	ngTEQ/m ³	
A2D1O531-01 A2D6260020001L 1# 焚烧炉废气排 气筒 (FQ- 0001) E:116°27'28" N:39°44'8" (第 1 次)	PCDFs	2,3,7,8-四氯代二苯并呋喃	2,3,7,8-T ₄ CDF	0.00067	0.00060	0.1	0.000060
		1,2,3,7,8-五氯代二苯并呋喃	1,2,3,7,8-P ₅ CDF	<0.0002	<0.0002	0.05	0.000006
		2,3,4,7,8-五氯代二苯并呋喃	2,3,4,7,8-P ₅ CDF	0.0013	0.0012	0.5	0.00058
		1,2,3,4,7,8-六氯代二苯并呋喃	1,2,3,4,7,8-H ₆ CDF	0.0012	0.0011	0.1	0.00011
		1,2,3,6,7,8-六氯代二苯并呋喃	1,2,3,6,7,8-H ₆ CDF	0.0012	0.0011	0.1	0.00011
		2,3,4,6,7,8-六氯代二苯并呋喃	2,3,4,6,7,8-H ₆ CDF	0.0022	0.0019	0.1	0.00019
		1,2,3,7,8,9-六氯代二苯并呋喃	1,2,3,7,8,9-H ₆ CDF	<0.0006	<0.0005	0.1	0.00003
		1,2,3,4,6,7,8-七氯代二苯并呋喃	1,2,3,4,6,7,8-H ₇ CDF	0.0039	0.0035	0.01	0.000035
		1,2,3,4,7,8,9-七氯代二苯并呋喃	1,2,3,4,7,8,9-H ₇ CDF	0.00090	0.00081	0.01	0.0000081
	八氯代二苯并呋喃	O ₈ CDF	0.0034	0.0031	0.001	0.0000031	
	PCDDs	2,3,7,8-四氯代二苯并-对-二噁英	2,3,7,8-T ₄ CDD	<0.0002	<0.0002	1	0.0001
		1,2,3,7,8-五氯代二苯并-对-二噁英	1,2,3,7,8-P ₅ CDD	<0.0007	<0.0006	0.5	0.0001
		1,2,3,4,7,8-六氯代二苯并-对-二噁英	1,2,3,4,7,8-H ₆ CDD	<0.0006	<0.0005	0.1	0.00003
		1,2,3,6,7,8-六氯代二苯并-对-二噁英	1,2,3,6,7,8-H ₆ CDD	<0.0005	<0.0004	0.1	0.00002
		1,2,3,7,8,9-六氯代二苯并-对-二噁英	1,2,3,7,8,9-H ₆ CDD	<0.0007	<0.0006	0.1	0.00003
		1,2,3,4,6,7,8-七氯代二苯并-对-二噁英	1,2,3,4,6,7,8-H ₇ CDD	0.0062	0.0056	0.01	0.000056
		八氯代二苯并-对-二噁英	O ₈ CDD	0.0077	0.0069	0.001	0.0000069
	二噁英类总量 I-TEQ			—	—	—	0.0015

备注: 1. I-TEQ (国际-毒性当量), 即样品中某多氯代二苯并二噁英 (PCDDs) 或多氯代二苯并呋喃 (PCDFs) 的浓度与其毒性当量因子 I-TEF 的乘积。
2. 未检出(N.D.)时毒性当量以检测限 1/2 计算。
3. 换算质量浓度(ρ): 二噁英类质量浓度的 11%含氧量换算值(ng/m³)
$$\rho = (21-11) / [21-\rho_s(O_2)] \times \rho_s$$
 式中 ρ_s(O₂) 废气中含氧量, %。

检测报告

No. A2D6260020001L

第 3 页, 共 5 页

样品名称和编号	检测项目	简称	实测浓度	换算浓度	毒性当量(TEQ)		
			ng/m ³	ng/m ³	I-TEF	ngTEQ/m ³	
A2D1O532-01 A2D6260020001L 1# 焚烧炉废气排 气筒 (FQ- 0001) E:116°27'28" N:39°44'8" (第 2 次)	PCDFs	2,3,7,8-四氯代二苯并呋喃	2,3,7,8-T ₄ CDF	0.00068	0.00069	0.1	0.000069
		1,2,3,7,8-五氯代二苯并呋喃	1,2,3,7,8-P ₅ CDF	0.00075	0.00076	0.05	0.000038
		2,3,4,7,8-五氯代二苯并呋喃	2,3,4,7,8-P ₅ CDF	<0.0006	<0.0006	0.5	0.0002
		1,2,3,4,7,8-六氯代二苯并呋喃	1,2,3,4,7,8-H ₆ CDF	0.00031	0.00031	0.1	0.000031
		1,2,3,6,7,8-六氯代二苯并呋喃	1,2,3,6,7,8-H ₆ CDF	0.00065	0.00066	0.1	0.000066
		2,3,4,6,7,8-六氯代二苯并呋喃	2,3,4,6,7,8-H ₆ CDF	0.00069	0.00069	0.1	0.000069
		1,2,3,7,8,9-六氯代二苯并呋喃	1,2,3,7,8,9-H ₆ CDF	<0.0006	<0.0006	0.1	0.00003
		1,2,3,4,6,7,8-七氯代二苯并呋喃	1,2,3,4,6,7,8-H ₇ CDF	0.0018	0.0018	0.01	0.000018
		1,2,3,4,7,8,9-七氯代二苯并呋喃	1,2,3,4,7,8,9-H ₇ CDF	<0.0004	<0.0004	0.01	0.000002
	八氯代二苯并呋喃	O ₈ CDF	0.0018	0.0018	0.001	0.0000018	
	PCDDs	2,3,7,8-四氯代二苯并-对-二噁英	2,3,7,8-T ₄ CDD	<0.0002	<0.0002	1	0.0001
		1,2,3,7,8-五氯代二苯并-对-二噁英	1,2,3,7,8-P ₅ CDD	<0.0006	<0.0006	0.5	0.0002
		1,2,3,4,7,8-六氯代二苯并-对-二噁英	1,2,3,4,7,8-H ₆ CDD	<0.0006	<0.0006	0.1	0.00003
		1,2,3,6,7,8-六氯代二苯并-对-二噁英	1,2,3,6,7,8-H ₆ CDD	<0.0005	0.00049	0.1	0.000049
		1,2,3,7,8,9-六氯代二苯并-对-二噁英	1,2,3,7,8,9-H ₆ CDD	<0.0006	<0.0006	0.1	0.00003
		1,2,3,4,6,7,8-七氯代二苯并-对-二噁英	1,2,3,4,6,7,8-H ₇ CDD	0.0018	0.0018	0.01	0.000018
		八氯代二苯并-对-二噁英	O ₈ CDD	0.0027	0.0027	0.001	0.0000027
	二噁英类总量 I-TEQ			—	—	—	0.00095

备注: 1. I-TEQ (国际-毒性当量), 即样品中某多氯代二苯并二噁英 (PCDDs) 或多氯代二苯并呋喃 (PCDFs) 的浓度与其毒性当量因子 I-TEF 的乘积。
2. 未检出(N.D.)时毒性当量以检测限 1/2 计算。
3. 换算质量浓度(ρ): 二噁英类质量浓度的 11%含氧质量换算值(ng/m³)
$$\rho = (21-11) / [21-\varphi_s(O_2)] \times \rho_s$$
 式中 $\varphi_s(O_2)$ 废气中含氧量, %。

检测报告

No. A2D6260020001L

第 4 页, 共 5 页

样品名称和编号	检测项目	简称	实测浓度	换算浓度	毒性当量(TEQ)		
			ng/m ³	ng/m ³	I-TEF	ngTEQ/m ³	
A2D1O533-01 A2D6260020001L 1# 焚烧炉废气排气筒 (FQ-0001) E:116°27'28" N:39°44'8" (第 3 次)	PCDFs	2,3,7,8-四氯代二苯并呋喃	2,3,7,8-T ₄ CDF	0.0012	0.0011	0.1	0.00011
		1,2,3,7,8-五氯代二苯并呋喃	1,2,3,7,8-P ₅ CDF	0.00034	0.00032	0.05	0.000016
		2,3,4,7,8-五氯代二苯并呋喃	2,3,4,7,8-P ₅ CDF	0.00065	0.00061	0.5	0.00030
		1,2,3,4,7,8-六氯代二苯并呋喃	1,2,3,4,7,8-H ₆ CDF	0.00040	0.00037	0.1	0.000037
		1,2,3,6,7,8-六氯代二苯并呋喃	1,2,3,6,7,8-H ₆ CDF	<0.0006	<0.0006	0.1	0.00003
		2,3,4,6,7,8-六氯代二苯并呋喃	2,3,4,6,7,8-H ₆ CDF	0.00055	0.00052	0.1	0.000052
		1,2,3,7,8,9-六氯代二苯并呋喃	1,2,3,7,8,9-H ₆ CDF	<0.0005	<0.0005	0.1	0.00003
		1,2,3,4,6,7,8-七氯代二苯并呋喃	1,2,3,4,6,7,8-H ₇ CDF	0.0017	0.0016	0.01	0.000016
		1,2,3,4,7,8,9-七氯代二苯并呋喃	1,2,3,4,7,8,9-H ₇ CDF	<0.0004	<0.0004	0.01	0.000002
	八氯代二苯并呋喃	O ₈ CDF	0.0015	0.0014	0.001	0.0000014	
	PCDDs	2,3,7,8-四氯代二苯并-对-二噁英	2,3,7,8-T ₄ CDD	<0.0002	<0.0002	1	0.0001
		1,2,3,7,8-五氯代二苯并-对-二噁英	1,2,3,7,8-P ₅ CDD	<0.0006	<0.0006	0.5	0.0001
		1,2,3,4,7,8-六氯代二苯并-对-二噁英	1,2,3,4,7,8-H ₆ CDD	<0.0005	<0.0005	0.1	0.00003
		1,2,3,6,7,8-六氯代二苯并-对-二噁英	1,2,3,6,7,8-H ₆ CDD	<0.0005	<0.0004	0.1	0.00002
		1,2,3,7,8,9-六氯代二苯并-对-二噁英	1,2,3,7,8,9-H ₆ CDD	<0.0006	<0.0006	0.1	0.00003
		1,2,3,4,6,7,8-七氯代二苯并-对-二噁英	1,2,3,4,6,7,8-H ₇ CDD	0.0019	0.0018	0.01	0.000018
		八氯代二苯并-对-二噁英	O ₈ CDD	0.0045	0.0042	0.001	0.0000042
	二噁英类总量 I-TEQ			—	—	—	0.00090

备注: 1. I-TEQ (国际-毒性当量), 即样品中某多氯代二苯并二噁英 (PCDDs) 或多氯代二苯并呋喃 (PCDFs) 的浓度与其毒性当量因子 I-TEF 的乘积。
 2. 未检出(N.D.)时毒性当量以检测限 1/2 计算。
 3. 换算质量浓度(ρ): 二噁英类质量浓度的 11%含氧质量换算值(ng/m³)
 $\rho = (21-11) / [21-\varphi_s(O_2)] \times \rho_s$ 式中 $\varphi_s(O_2)$ 废气中含氧量, %。

检测报告

No. A2D6260020001L

第 5 页, 共 5 页

排气筒参数

项目	1# 焚烧炉废气排气筒 (FQ-0001)		
	第 1 次	第 2 次	第 3 次
排气筒高度 (m)	80		
截面积 (m ²)	4.1548		
测点烟气温度(°C)	148	148	149
烟气平均流速(m/s)	13.3	13.6	13.9
标态干烟气流(m ³ /h)	101000	105000	108000
烟气流量(m ³ /h)	199276	203786	208021
烟气含氧量(%)	9.9	11.1	10.3
含湿量(%)	21.0	19.5	18.4
测定均值(ng TEQ/ m ³)	0.0011		

——以下空白——

